

Part no.

FAT•N Powering Business Worldwide[™]

M22S-R4K7 Article no. 232232 Catalog No. M22S-R4K7Q

Delivery programme

| Basic function | | | Potentiometer |
|----------------------------|---|----|--|
| Single unit/Complete unit | | | Single unit |
| Description | | | 3 individual screw terminals Accuracy of resistance value: ± 10% (linear) |
| Contact sequence | | | |
| Impedance | R | kΩ | 4.7 |
| Rated power | Р | W | 0.5 |
| Degree of Protection | | | IP66 |
| Front ring | | | Front ring: black |
| Connection to SmartWire-DT | | | no |
| | | | |

Technical data General

| Gonora | | | |
|---------------------------------------|------------------|-----------------|--|
| Standards | | | IEC/EN 60947 VDE 0660 |
| Climatic proofing | | | Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 |
| Ambient temperature | | °C | |
| Open | | °C | -25 - +70 |
| Mounting position | | | As required |
| Mechanical shock resistance | | g | 30 Shock duration 11 ms Sinusoidal according to IEC 60068-2-27 |
| Terminal capacities | | mm ² | |
| Solid | | mm ² | 0.5 - 1.5 |
| Stranded | | mm ² | 0.5 - 1.5 |
| Contacts | | | |
| Rated impulse withstand voltage | U _{imp} | V AC | 4000 |
| Rated insulation voltage | Ui | V | 250 |
| Overvoltage category/pollution degree | | | 111/3 |

Design verification as per IEC/EN 61439

| Technical data for design verification | | | |
|--|-------------------|----|--|
| Rated operational current for specified heat dissipation | In | А | 0 |
| Heat dissipation per pole, current-dependent | P _{vid} | W | 0 |
| Equipment heat dissipation, current-dependent | P _{vid} | W | 0 |
| Static heat dissipation, non-current-dependent | P _{vs} | W | 0.5 |
| Heat dissipation capacity | P _{diss} | W | 0 |
| Operating ambient temperature min. | | °C | -25 |
| Operating ambient temperature max. | | °C | 70 |
| IEC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |

| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | Meets the product standard's requirements. |
|--|--|
| 10.2.4 Resistance to ultra-violet (UV) radiation | Please enquire |
| 10.2.5 Lifting | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | Is the panel builder's responsibility. |
| 10.9 Insulation properties | |
| 10.9.2 Power-frequency electric strength | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility. |
| 10.10 Temperature rise | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 6.0

Low-voltage industrial components (EG000017) / Potentiometer for control circuit devices (EC001027)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Potentiometer for command devices (ecl@ss8.1-27-37-12-27 [AKF045011])
Resistance

| nesistance | UIIII | 4700 |
|---------------------------|-------|------|
| Power consumption | W | 0.5 |
| Hole diameter | mm | 22 |
| Degree of protection (IP) | | IP66 |

| Product StandardsFor Gusta StandardsEC/EN 60947-5; UL 508; CSA-C22.2 No. 14-05; CSA-C22.2 No. 94-91; CE markingUL File No.E9184CSA File No.NKCRCSA Class No.12528North America CertificationUL isted, CSA certified | Approvals | |
|---|-----------------------------|--|
| UL File No. E9184 UL Category Control No. NKCR CSA File No. Image: CSA Class No. North America Certification Image: CSA Class No. | Product Standards | IEC/EN 60947-5; UL 508; CSA-C22.2 No. 14-05; CSA-C22.2 No. 94-91; CE marking |
| UL Category Control No. MKCR CSA File No. 12528 CSA Class No. 3211-03 North America Certification Mode Certified | UL File No. | E29184 |
| CSA File No. Image: CSA Class No. North America Certification Image: CSA Class No. | UL Category Control No. | NKCR |
| CSA Class No. 3211-03 North America Certification UL listed, CSA certified | CSA File No. | 012528 |
| North America Certification UL listed, CSA certified | CSA Class No. | 3211-03 |
| | North America Certification | UL listed, CSA certified |
| Degree of Protection UL/CSA Type 3R, 4X, 12, 13 | Degree of Protection | UL/CSA Type 3R, 4X, 12, 13 |





Additional product information (links)

IL04716002Z (AWA1160-1745) RMQ-Titan System

IL04716002Z (AWA1160-1745) RMQ-Titan ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/IL04716002Z2015_02.pdf System