

Part no.

Article no.

Catalog No.

M22-LH-R 216779 M22-LH-RQ



## Delivery programme

Product range	RMQ-Titan (drilling dimensions 22.5 mm)
Basic function	Indicator lights
Single unit/Complete unit	Single unit
Design	Extended, conical
Colour	
Lens	Red
Lens	
Degree of Protection	IP67, IP69K
Front ring	Front ring: titanium
Connection to SmartWire-DT	Yes, with SWD-RMQ connections
Front dimensions	29,7

#### Technical data General

General			
Standards			IEC/EN 60947 VDE 0660
Climatic proofing			Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30
Ambient temperature		°C	
Open		°C	-25 - +70
Mounting position			As required
Mechanical shock resistance		g	30 Shock duration 11 ms Sinusoidal according to IEC 60068-2-27
Terminal capacities		mm <sup>2</sup>	
Solid		mm <sup>2</sup>	0.5 - 1.5
Stranded		mm <sup>2</sup>	0.5 - 1.5
Contacts			
Rated impulse withstand voltage	U <sub>imp</sub>	V AC	4000
Rated insulation voltage	Ui	V	250
Overvoltage category/pollution degree			III/3

## Design verification as per IEC/EN 61439

I <sub>n</sub>	А	0
P <sub>vid</sub>	W	0
P <sub>vid</sub>	W	0
P <sub>vs</sub>	W	0
P <sub>diss</sub>	W	0
	°C	-25
	°C	70
		Meets the product standard's requirements.
	P <sub>vid</sub> P <sub>vid</sub> P <sub>vs</sub>	P <sub>vid</sub> W P <sub>vid</sub> W P <sub>vs</sub> W P <sub>diss</sub> W °C

102.3.1 Verification of thermal stability of enclosures   Image: Construction of resistance of insulating materials to normal heat and fired use to internal electric effects   Metes the product standard's requirements.     102.3.3 Verification of resistance of insulating materials to abnormal heat and fired use to internal electric effects   Metes the product standard's requirements.     102.4 Resistance to ultra-violet (UV) radiation   Metes the product standard's requirements.     102.5 Lifting   Does not apply, since the entire switchgear needs to be evaluated.     102.7 Inscriptions   Metes the product standard's requirements.     103.2 Begree of protection of ASSEMBLIES   Metes the product standard's requirements.     103.4 Clearances and crepage distances   Metes the product standard's requirements.     104.7 Clearances and components   Metes the product standard's requirements.     105.2 Protection against electric shock   Metes the product standard's requirements.     104.7 Internal electrical circuits and components   Metes the product standard's requirements.     105.2 Protection against electric shock   Metes the product standard's requirements.     104.2 Prover-frequency electric strength   Is the panel builder's responsibility.     104.2 Prover-frequency electric strength   Is the panel builder's responsibility.     10.3 Inpulse withstand voltage   Is the panel builder's responsibility.		
10.2.3.3 Verification of resistance of insulating materials to abnormal head and fire due to internal electric effects   Meets the product standard's requirements.     10.2.4 Resistance to ultra-violet (UV) radiation   Please enquire     10.2.5 Lifting   Dees not apply, since the entire switchgear needs to be evaluated.     10.2.6 Mechanical impact   Dees not apply, since the entire switchgear needs to be evaluated.     10.2.7 Inscriptions   Meets the product standard's requirements.     10.3 Degree of protection of ASSEMBLIES   Dees not apply, since the entire switchgear needs to be evaluated.     10.4 Clearances and creepage distances   Dees not apply, since the entire switchgear needs to be evaluated.     10.8 Concection of assiching devices and components   Dees not apply, since the entire switchgear needs to be evaluated.     10.8 Connections for external conductors   Step panel builder's responsibility.     10.9 Insulation properties   Is the panel builder's responsibility.     10.9 Insulation properties   Is the panel builder's responsibility.     10.9 Tomperature rise   Is the panel builder's responsibility.     10.11 Short-circuit rating	10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
and fire due to internal electric effects     And fire due to internal electric effects     And fire due to internal electric effects       10.2.4 Resistance to ultra-violet (UV) radiation     Please enquire       10.2.5 Lifting     Does not apply, since the entire switchgear needs to be evaluated.       10.2.6 Mechanical impact     Does not apply, since the entire switchgear needs to be evaluated.       10.2.7 Inscriptions     Meets the product standard's requirements.       10.3.0 agree of protection of ASSEMBLIES     Does not apply, since the entire switchgear needs to be evaluated.       10.4 Clearances and creepage distances     Meets the product standard's requirements.       10.5 Protection against electric shock     Does not apply, since the entire switchgear needs to be evaluated.       10.6 Incorporation of switching devices and components     Does not apply, since the entire switchgear needs to be evaluated.       10.7 Internal electrical circuits and connections     Is the panel builder's responsibility.       10.8 Connections for external conductors     Is the panel builder's responsibility.       10.9 Insulation properties     Is the panel builder's responsibility.       10.9 Insulation group electric strength     Is the panel builder's responsibility.       10.9 Temperature rise     Not applicable.       10.10 Temperature rise     Is the panel builder's resp	10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.5 Lifting   Does not apply, since the entire switchgear needs to be evaluated.     10.2.6 Mechanical impact   Does not apply, since the entire switchgear needs to be evaluated.     10.3.1 Degree of protection of ASSEMBLIES   Does not apply, since the entire switchgear needs to be evaluated.     10.4 Clearances and creepage distances   Does not apply, since the entire switchgear needs to be evaluated.     10.5 Protection against electric shock   Does not apply, since the entire switchgear needs to be evaluated.     10.7 Internal electrical circuits and components   Does not apply, since the entire switchgear needs to be evaluated.     10.8 Connections for external conductors   Does not apply, since the entire switchgear needs to be evaluated.     10.9 Insulation properties   Is the panel builder's responsibility.     10.9.1 Shower-frequency electric strength   Is the panel builder's responsibility.     10.9.2 Power-frequency electric strength   Is the panel builder's responsibility.     10.9.3 Impulse withstand voltage   Is the panel builder's responsibility.     10.9.1 Temperature rise   Not applicable.     10.1.1 Short-circuit rating   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.1.3 Mechanical function   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.1.3 Mechanical function		Meets the product standard's requirements.
10.2.8 Mechanical impact   Does not apply, since the entire switchgear needs to be evaluated.     10.2.7 Inscriptions   Meets the product standard's requirements.     10.3 Degree of protection of ASSEMBLIES   Does not apply, since the entire switchgear needs to be evaluated.     10.4 Clearances and creepage distances   Meets the product standard's requirements.     10.5 Protection against electric shock   Does not apply, since the entire switchgear needs to be evaluated.     10.6 Incorporation of switching devices and components   Does not apply, since the entire switchgear needs to be evaluated.     10.7 Internal electrical circuits and connections   Is the panel builder's responsibility.     10.8 Connections for external conductors   Is the panel builder's responsibility.     10.9.1 Nuslation properties   Is the panel builder's responsibility.     10.9.2 Power-frequency electric strength   Is the panel builder's responsibility.     10.9.3 Impulse withstand voltage   Is the panel builder's responsibility.     10.9.4 Testing of enclosures made of insulating material   Is the panel builder's responsibility.     10.11 Short-circuit rating   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.13 Mechanical function   Is the panel builder's responsibility. The specifications for the switchgear must be observed.	10.2.4 Resistance to ultra-violet (UV) radiation	Please enquire
10.2.7 Inscriptions   Meets the product standard's requirements.     10.3 Degree of protection of ASSEMBLIES   Does not apply, since the entire switchgear needs to be evaluated.     10.4 Clearances and creepage distances   Meets the product standard's requirements.     10.5 Protection against electric shock   Does not apply, since the entire switchgear needs to be evaluated.     10.6 Incorporation of switching devices and components   Does not apply, since the entire switchgear needs to be evaluated.     10.7 Internal electrical circuits and connections   Is the panel builder's responsibility.     10.8 Connections for external conductors   Is the panel builder's responsibility.     10.9.1 nsulation properties   Is the panel builder's responsibility.     10.9.2 Power-frequency electric strength   Is the panel builder's responsibility.     10.9.3 Inpulse withstand voltage   Is the panel builder's responsibility.     10.9.4 Testing of enclosures made of insulating material   Is the panel builder's responsibility.     10.11 Short-circuit rating   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.13 Mechanical function   The device meets the requirements, provided the information in the instruction	10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.3 Degree of protection of ASSEMBLIES   Dees not apply, since the entire switchgear needs to be evaluated.     10.4 Clearances and creepage distances   Meets the product standard's requirements.     10.5 Protection against electric shock   Does not apply, since the entire switchgear needs to be evaluated.     10.6 Incorporation of switching devices and components   Does not apply, since the entire switchgear needs to be evaluated.     10.7 Internal electrical circuits and connections   Is the panel builder's responsibility.     10.8 Connections for external conductors   Is the panel builder's responsibility.     10.9 Insulation properties   Is the panel builder's responsibility.     10.9.2 Power-frequency electric strength   Is the panel builder's responsibility.     10.9.3 Inpulse withstand voltage   Is the panel builder's responsibility.     10.9.4 Testing of enclosures made of insulating material   Is the panel builder's responsibility.     10.10 Temperature rise   Not applicable.     10.12 Electromagnetic compatibility.   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.13 Mechanical function   The device meets the requirements, provided the information in the instruction	10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances   Meets the product standard's requirements.     10.5 Protection against electric shock   Does not apply, since the entire switchgear needs to be evaluated.     10.6 Incorporation of switching devices and components   Does not apply, since the entire switchgear needs to be evaluated.     10.7 Internal electrical circuits and connections   Is the panel builder's responsibility.     10.8 Connections for external conductors   Is the panel builder's responsibility.     10.9 Insulation properties   Is the panel builder's responsibility.     10.9.2 Power-frequency electric strength   Is the panel builder's responsibility.     10.9.3 Impulse withstand voltage   Is the panel builder's responsibility.     10.10 Temperature rise   Not applicable.     10.11 Short-circuit rating   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.12 Electromagnetic compatibility   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.13 Mechanical function   It the panel builder's responsibility. The specifications for the switchgear must be observed.	10.2.7 Inscriptions	Meets the product standard's requirements.
10.5 Protection against electric shock   Des not apply, since the entire switchgear needs to be evaluated.     10.6 Incorporation of switching devices and components   Does not apply, since the entire switchgear needs to be evaluated.     10.7 Internal electrical circuits and connections   Is the panel builder's responsibility.     10.8 Connections for external conductors   Is the panel builder's responsibility.     10.9 Insulation properties   Is the panel builder's responsibility.     10.9.2 Power-frequency electric strength   Is the panel builder's responsibility.     10.9.3 Impulse withstand voltage   Is the panel builder's responsibility.     10.9.1 Temperature rise   Is the panel builder's responsibility.     10.11 Short-circuit rating   Is the panel builder's responsibility.     10.12 Electromagnetic compatibility   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.13 Mechanical function   The device meets the requirements, provided the information in the instruction	10.3 Degree of protection of ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components   Does not apply, since the entire switchgear needs to be evaluated.     10.7 Internal electrical circuits and connections   Is the panel builder's responsibility.     10.8 Connections for external conductors   Is the panel builder's responsibility.     10.9 Insulation properties   Is the panel builder's responsibility.     10.9.2 Power-frequency electric strength   Is the panel builder's responsibility.     10.9.3 Impulse withstand voltage   Is the panel builder's responsibility.     10.9.4 Testing of enclosures made of insulating material   Is the panel builder's responsibility.     10.11 Short-circuit rating   Not applicable.     10.12 Electromagnetic compatibility   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.13 Mechanical function   The device meets the requirements, provided the information in the instruction	10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.7 Internal electrical circuits and connections   Is the panel builder's responsibility.     10.8 Connections for external conductors   Is the panel builder's responsibility.     10.9 Insulation properties   Is the panel builder's responsibility.     10.9.2 Power-frequency electric strength   Is the panel builder's responsibility.     10.9.3 Impulse withstand voltage   Is the panel builder's responsibility.     10.9.4 Testing of enclosures made of insulating material   Is the panel builder's responsibility.     10.10 Temperature rise   Not applicable.     10.11 Short-circuit rating   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.12 Electromagnetic compatibility   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.13 Mechanical function   The device meets the requirements, provided the information in the instruction	10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors   Is the panel builder's responsibility.     10.9 Insulation properties   Is the panel builder's responsibility.     10.9.2 Power-frequency electric strength   Is the panel builder's responsibility.     10.9.3 Impulse withstand voltage   Is the panel builder's responsibility.     10.9.4 Testing of enclosures made of insulating material   Is the panel builder's responsibility.     10.10 Temperature rise   Not applicable.     10.11 Short-circuit rating   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.12 Electromagnetic compatibility   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.13 Mechanical function   The device meets the requirements, provided the information in the instruction	10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.9 Insulation properties   Image: Section of the sectin of the sectin of the section of the section of the sec	10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.9.2 Power-frequency electric strength   Is the panel builder's responsibility.     10.9.3 Impulse withstand voltage   Is the panel builder's responsibility.     10.9.4 Testing of enclosures made of insulating material   Is the panel builder's responsibility.     10.10 Temperature rise   Not applicable.     10.11 Short-circuit rating   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.12 Electromagnetic compatibility   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.13 Mechanical function   The device meets the requirements, provided the information in the instruction	10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage   Is the panel builder's responsibility.     10.9.4 Testing of enclosures made of insulating material   Is the panel builder's responsibility.     10.10 Temperature rise   Not applicable.     10.11 Short-circuit rating   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.12 Electromagnetic compatibility   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.13 Mechanical function   The device meets the requirements, provided the information in the instruction	10.9 Insulation properties	
10.9.4 Testing of enclosures made of insulating material   Is the panel builder's responsibility.     10.10 Temperature rise   Not applicable.     10.11 Short-circuit rating   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.12 Electromagnetic compatibility   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.13 Mechanical function   The device meets the requirements, provided the information in the instruction	10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.10 Temperature rise   Not applicable.     10.11 Short-circuit rating   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.12 Electromagnetic compatibility   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.13 Mechanical function   The device meets the requirements, provided the information in the instruction	10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.11 Short-circuit rating   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.12 Electromagnetic compatibility   Is the panel builder's responsibility. The specifications for the switchgear must be observed.     10.13 Mechanical function   The device meets the requirements, provided the information in the instruction	10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed.   10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.10 Temperature rise	Not applicable.
10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.11 Short-circuit rating	
	10.12 Electromagnetic compatibility	
	10.13 Mechanical function	

### **Technical data ETIM 6.0**


Low-voltage industrial components (EG000017) / Front element for indicator light (EC000223)


Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for warning lights (ecl@ss8.1-27-37-12-11 [AKF029011])


Suitable for number of built-in signal lights		1
Colour lens		Red
Construction type lens		Round
Hole diameter	mm	22
Width opening	mm	22
Height meter opening	mm	6
With front ring		Yes
Material front ring		Plastic
Colour front ring		Chrome
Type of lens		High
Degree of protection (IP), front side		IP67


#### **Approvals**

JL File No. E29184 JL Category Control No. CSA File No. CSA Class No. C	- PP	
JL Category Control No. NKCR   CSA File No. 012528   CSA Class No. 01	Product Standards	IEC/EN 60947-5; UL 508; CSA-C22.2 No. 14-05; CSA-C22.2 No. 94-91; CE marking
CSA File No. 012528   CSA Class No. 3211-03	UL File No.	E29184
CSA Class No. 3211-03	UL Category Control No.	NKCR
	CSA File No.	012528
North America Certification UL listed, CSA certified	CSA Class No.	3211-03
	North America Certification	UL listed, CSA certified
Degree of Protection UL/CSA Type 3R, 4X, 12, 13	Degree of Protection	UL/CSA Type 3R, 4X, 12, 13









(1) Top-hat rail to IEC/EN 60715

# Additional product information (links)

### IL04716002Z (AWA1160-1745) RMQ-Titan System

IL04716002Z (AWA1160-1745) RMQ-Titan ftp://ftp.moeller.net/DOCUMENTATION/AWA\_INSTRUCTIONS/IL04716002Z2015\_02.pdf System